

PORTABLE APPLIANCE INSPECTION AND TEST CHECKLIST AND RECORD SHEET

INSPECTION AND TEST CHECKLIST

Item	Pass Condition
Mains Lead	Two layers of insulation on all parts outside plug and case.
	No cuts, cracks, kinks, fraying or taped repairs.
	Cable protected by grommet or other means at entry point to equipment.
	No appreciable movement of lead at entry point to equipment.
Mains Plug	Body not damaged.
	Sleeved pins fitted where children are present.
	Cable sheath gripped securely.
	Correct fuse fitted.
	Correctly connected (re-wireable units).
	Wires secure in pins (re-wireable units).
	Cover securely attached.
Mains Lead Equipment Connector (if lead is detachable) and sockets on extension leads	Body not damaged.
	Unopenable without a tool.
	Cable sheath gripped securely.
Equipment Male Connector (if lead is detachable)	Pins straight and in good condition.
Mains on/off Switch	No damage and correct operation.
Class 1 Equipment	Case not damaged, vents clear of dust and dirt.
	Earth resistance less than 0.1Ω or 0.5Ω if fused at 3A or less.
	Insulation resistance above 2MΩ.
Class 2 Equipment	Case not damaged, vents clear of dust and dirt.
	Insulation resistance above 7MΩ.
Accessible Fuse Holders	No damage.
	Removal of the carrier does not permit live parts to be touched.
Exposed Output Connections	No voltage greater than 50V.

PORTABLE APPLIANCE INSPECTION AND TEST RECORD SHEET

Date 17th June 2025	Sheet 1 of 2
---------------------	--------------

ESTABLISHMENT: Ultimate Rodeo Bulls
--

PERSON CARRYING OUT INSPECTIONS AND TESTS: B Poulter - brp electrical
--

Location	Equip. No.	Description	Class	*Pass/Fail	Comments
Stores	1	Blower	2	Pass	None
Stores	2	LED Light 1	2	Pass	None
Stores	3	LED Light 2	2	Pass	None
Stores	4	4 way Extension	2	Pass	None
Stores	5	4 way Extension Yellow	2	Pass	None
Stores	6	Ibbons Blower	2	Pass	None
Stores	7	Blower Lead	2	Pass	None
Stores	8	Mic Leads	1	Pass	None
Stores	9	Mic Leads	1	Pass	None
Stores	10	Mic Leads	1	Pass	None
Stores	11	Mic Leads	1	Pass	None
Stores	12	Mic Leads	1	Pass	None
Stores	13	JBL Speaker 1	1	Pass	None
Stores	14	JBL Speaker 2	2	Pass	None
Stores	15	JBL Lead	2	Pass	None
Stores	16	JBL Lead	2	Pass	None
Stores	17	Rodeo Clock	2	Pass	None
Stores	18	Blower	2	Pass	None
Stores	19	Blower lead	2	Pass	None
Stores	20	Yellow Blower	2	Pass	None

PORTABLE APPLIANCE INSPECTION AND TEST RECORD SHEET

Date Date 17th June 2025

Sheet 2 of 2

ESTABLISHMENT: Ultimate Rodeo Bulls

PERSON CARRYING OUT INSPECTIONS AND TESTS: B Poulter - brp electrical

Location	Equip. No.	Description	Class	*Pass/Fail	Comments
Stores	21	Yellow Blower	2	Pass	None
Stores	22	Euro Adaptor	2	Pass	None
Stores	23	Euro Adaptor	2	Pass	None
Stores	24	4 Way Extension	2	Pass	None
Stores	25	6 Way Extension	2	Pass	None
Stores	26	Euro Plug	2	Pass	None
Stores	27	Kettle Lead	2	Pass	None
Stores	28	Kettle Lead	2	Pass	None
Stores	29	Kettle Lead	2	Pass	None
Stores	30	40m Extention	2	Pass	None
Stores	31	45m Extention	2	Pass	None
Stores	32	Flood Light	2	Pass	None
Stores	33	Led Tube	2	Pass	None
Stores	34	Led Light LAP	2	Pass	None
Stores	35	2 way Extension	2	Pass	None
Stores	36	4 Way Extension Red	2	Pass	None
Stores	37	4 Way Extension Yellow	2	Pass	None
Stores	38	4 Way Extension Red	2	Pass	None
Stores	39	4 Way Extension	2	Pass	None
Stores	40	4 Way Extension	2	Pass	None